

Novinky



VLHKOSTNĚ-TEPLOTNÍ SONDY DSRH PRO ETHERNETOVÉ SNÍMAČE ŘADY P8xx1

Vlhkostně-teplotní sonda s digitálním senzorem pro Ethernetové převodníky P8xx1 s rozsahem 0 až 50°C.

VLHKOSTNĚ-TEPLOTNÍ SONDY DSRH PRO ETHERNETOVÉ SNÍMAČE ŘADY P8xx1

- sonda vlhkost/teplota určena pro mírně náročné nasazení
- hlavní nasazení: IT, monitoring běžných kancelářských prostor, monitoring skladů s teplotami 0 až 50°C, atd.
- pro podporu sond DSRH v dříve zakoupených přístrojích P8xx1 je nutný upgrade na nový firmware v přístroji, který je ke stažení na: 4-5-5-03

Pracovní rozsah teploty: 0 až +50°C

Pracovní rozsah relativní vlhkosti: 0 až 100% RH (bez kondenzace)

Přesnost měření relativní vlhkosti: $\pm 3.5\%$ RH (10% – 90% RH) při 25°C

Přesnost měření teploty: $\pm 2^\circ\text{C}$

Mezní teplotní podmínky (omezené použití): -30 až +80°C

Krytí: IP40

Podporované jednotky: %RH, °C, F

Filtrační schopnost krytky čidel: 0.025mm - filtr s nerezovou tkaninou

Podporované přístroje: P8511, P8541, P8631

Konektor: CINCH

Podporovaný firmware v převodníku P8xx1 4-5-5-00 nebo novější

click here to try
online demo

P8541



PoE sniamec na stene

192.168.1.121

Issue: 09:02:01 2017-06-15

U/I: 10949004

Channel 1

24.3°C
alarm none

History	History
.csv dot	.csv comma
Mobile	Refresh
web	page
Settings	About
*	?

Copyright © 2012, Comet systems s.r.o. All rights reserved.

Settings Email

Configuration of the alarm email. Please use valid e-mailing email when alarm or threshold alarm occurs. Email of channel will be used as default.

SMTP server configuration

SMTP server IP address: 192.168.1.2

SMTP server port: 25

SMTP authentication:

Email configuration

Email sender address: alarm@comet-system.com

Recipient 1: jankov@comet-system.com

Recipient 2:

Recipient 3:

Short e-mail:

Alarm report sending interval: 1 hr

Info email report sending interval: 1 hr

Repeat email attachment: Email_alarm_en

Save settings | Test settings | Cancel changes

Ethernet Transducer


192.168.1.42

Local time: Friday, June 15, 2012 09:06:37

U/I: 10949004

Channel 2	25.6°C alarm none	History	History
Channel 4	n/a alarm none	Mobile	Refresh
		web	page
		Settings	About
		*	?

rights reserved.



PoE sniamec na stene

192.168.1.121

Issue: 09:30:53 2017-06-15

U/I: 10949004

Channel 1

24.4°C
alarm none

Back

Refresh page